

2430 "E" Street, N. W.
Washington, D. C.
12 March 1954

25X1A9a



Subject:



25X1A

Lawn Hose Valve and Box

25X1A9a

Dear



Your letter of 5 March 1954, with reference to the lawn hose valve and box for the subject station has been reviewed and the following comments are made:


a. Since the No. 58 Crane hose valve appears to be rather sturdy, it is not believed that the handwheel will slip as mentioned. Please check with the attached "cut" of the valve to determine if the plumber is using the valve specified. You may retain the catalog sheet for your files, if desired.

b. The question of the size of the concrete valve box and cast iron cover resolves itself into the size of the valve to be used. The plumber must provide a box of suitable size to permit easy operation of the valve and a cover of proper size for the box used.

The additional fittings and equipment are not considered necessary under the foregoing circumstances.

Very truly yours,

25X1A9a



Enclosure